

5-10. SNP/F&ESS/80/206 12024

dt-28/6/2024

GOVT. OF ASSAM
SONAPUR FIRE & EMERGENCY SERVICES STATION,
ASSAM, GUWAHATI.



No. SNP/ F&ESS/
To,

Dated 28/6/2024

The Principal,
Rajdhani Public School,
Nazirakhat, Sonapur,
Dist:- Kamrup (M), Assam.

Sub:- Additional Fire Safety measures recommendation.

Ref:- Nil
Sir,


In inviting a reference above, I am to inform you that the following additional fire safety measures as per National Building Code of India, 2016, Part IV are to be implemented in your School building at Nazirakhat, Sonapur, Guwahati.

1. Down Comer system should be provided in the building.
2. Hose reel hose system should be provided in each floor of the building.
3. Manually Operated Electric Fire Alarm system should be provided in the building.
4. Terrace Water tank capacity of 25,000 lts. with Terrace Pump 900 LPM should be provided.

Submit compliance report to the undersigned for further necessary action from this end.

This is for your kind information and necessary action.

Yours faithfully


28/6/2024

Station Officer,

Sonapur Fire & Emergency Services Station
Assam, Guwahati.

Station Officer
Sonapur Fire & E.S. Station
Assam, Sonapur, Gity.